

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7160-1283:102 Page 1 of 1

CATEGORY: Cables-Others

LISTEE: General Cable Corporation, 4 Tesseneer Dr., Highland Heights, KY 41076-9753
Contact: *Tom Herbort (859) 572-8020 Fax (859) 572-8447

DESIGN: Type Class 2 and CL2P power limited circuit cables.

Insulation - PFA, FEP Teflon; semi-rigid PVC Cary 1360 or PVDF Copolymer Solef 11008-0003/11010-0003.

Shields - (Optional) All metal, polyethylene terephthalate/metal or Aluminum-polyester tape.

Core Wraps - (Optional) Glass reinforced TFE Teflon impregnated tape or polyethylene terephthalate.

Jacket - Kynar 460; Solef 3008, 11008-0003/11010-0003; PVDF; PFA 310/340, FEP Teflon, Daikin FEP NP-20/30/40 or PVC Gary GW 3000D.

Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, NEC Article 725, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, type CL2 or CL2P, rating and UL label.

APPROVAL: Listed as Class 2 power-limited circuit cable.

NOTE: Formerly 7160-0876:101

*Rev. 06-05-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 16, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**